

Amendment to tender enquiry no. NIPER-G/99/FUR/Incubation Centre/2019-20 dated 19/10/2020 for Laboratory Furniture of Third Floor Right wing (Incubation Centre) at Academic Block A

As per the Pre-Bid Meeting held at NIPER-G, Changsari on 27/10/2020

Sl. No.	Tender Specifications/Conditions	Amended Specifications/Conditions
1.	Page No. 62 Under Bench Module on 'C' frame. The Entire Module Should Be Made Up Of GI Panels And Are Bolted For High Corrosion Resistance. Welding Of Modules Is Not Acceptable. The Shutters Should Be Mounted To The Modules By Hinges Which Are Openable To 95 Degree & Self closing On Return.	Modules on C-frame should be completely welded with removable doors and back panel as per SEFA 8M. The shutters should be mounted to the modules by hinges which are openable to 160 to 210 degree & self closing on return.
2.	Page No. 61 C Frame Assembly	SEFA 8M and/or SEFA 10 compliance certificate for C-Frame Assembly will be considered.
3.	Drawings	Enclosed as Annexure 1
4.	EMD = 300000/-	Firms registered under MSME will be exempted from submission of EMD.
5.	As mentioned in Page No. 2 of tender documents, "Vendor should have prior experience for the installation of such kind of furniture at Central Government Educational and R & D organizations in North Eastern India and must have Executed at least 5 such projects"	Vendor should have prior experience for the installation of such kind of furniture at Central Government Educational and R & D organizations in North Eastern India and must have executed at least 3 such projects during the last 5 years.
6.	It is mentioned in the tender to submit the tender documents in two sets, i.e. ORIGINAL BID & COPY BID.	Only one set of tenders in original should be submitted. No other copy is required.
7.	It is mentioned on Page No 74 that vendor should have SATARA certificate for the storage product.	SATARA certificate for the storage products is mandatory.
8.	As mentioned on Page No 61 in C frame structure "Drainage gradient should be well adjusted throughout the length of table and should have horizontal supports for drainage systems."	As per the given drawings, sinks are kept on the C-frame structure. Drainage is required on the benches.
9.	Polyamide Hinges from outside of Base Cabinet (Pg No 71)	SS butt hinges for Base Cabinet will be considered.
10.	Apparatus Holding Grid - Duralumin Powder coated rod (Pg No 71)	MOC of Apparatus Holding Grid as epoxy rods will be considered.
11.	Delivery time: 2-3 weeks from the date of	Revised delivery period is 3-4

	purchase order (Pg No 74)	weeks from the date of G.A. drawing and colourshade approval.
12.	GST %	GST concession is available to NIPER-Guwahati
13.	Warranty	03 years comprehensive warranty should be valid for the entire furniture. AMC rates should be quoted for the fourth and fifth year separately.
14.	Chapter 4: Eligibility Criteria	If NIPER-G or any of its sister organizations is having any past unsatisfactory experience with any vendor, such vendor is not entitled to participate in this tendering.