



राष्ट्रीय औषधीय शिक्षा तथा अनुसंधान संस्थान गुवाहाटी
**NATIONAL INSTITUTE OF PHARMACEUTICAL
EDUCATION AND RESEARCH-GUWAHATI**

(Department of Pharmaceuticals, Ministry of Chemicals and Fertilizers, Govt. of India)
SilaKatamur (Halugurisuk), P.O.: Changsari, Dist: Kamrup, Assam, Pin: 781101.

Ref. No. NIPER-G/91/S&P/UPS/2021-22

Date: 11/01/2022

CORRIGENDUM

Subsequent to the pre-bid meeting held on 04/01/2022 for UPS in reference to the tender enquiry no. NIPER-G/91/S&P/UPS/2021-22 dated 29/12/2021, the following amendments may be noted:

Sl. No.	Comments received from vendor	Vendor	Amendments
1.	To consider Ingress protection (IP21 as IP20)	M/s Kalcom System/M/s Delta Electronics India Pvt. Ltd.	No amendment.
2.	To consider that bidder can participate without having Govt Electrical Licence	M/s Kalcom System/M/s Delta Electronics India Pvt. Ltd.	No amendment.
3.	To consider OEM's credential (as bidder credentials where bidder is not a manufacturer)	M/s Kalcom Sytem/M/s Delta Electronics India Pvt. Ltd.	This is fine and it is already there in the previous specification list.
4.	Requested to add that bidder should have necessary infrastructure and resources for providing timely and effective after sales service support.	M/s DS Systems Pvt. Ltd.	Bidder's experience are as follows: "Bidder should have experience in supply, installation and commissioning of at least 5 units of similar UPS system of capacity not less than 40KVA in any government department, PSU or autonomous body in Assam/NE."

Additional incorporation:

- A. The quantity of 40 kVA UPS is changed from 05 nos. to 06 nos.
- B. Experience of the bidder:
- a. The bidder should have experience in supply, installation and commissioning of at least 5 units of similar UPS system of capacity not less than 40KVA in any government department, PSU or autonomous body in Assam/NE. PO copies along with completion certificates and client details shall be submitted.
 - b. Bidder should have at least two (2) ongoing services and maintenance contract of UPS system of capacity not less than 40KVA in any government department, PSU and autonomous body in Assam/NE. Copies of such maintenance service contract shall be submitted as proof.
 - c. Type Test Report: Bidder shall submit type test (performance) certificate (as per IEC-62040-3 STANDARD) FROM UL/TUV or equivalent certified laboratories.

This is for information of all the bidders.


Stores & Purchase Officer
NIPER-Guwahati